

Notification for Underground Storage Tanks

FORM APPROVED
OMB NO. 2050-0068
APPROVAL EXPIRES 9-30-91

DIVISION PETROLEUM/CHEMICAL SAFETY
ILLINOIS STATE FIRE MARSHAL
135 STEVENSON DRIVE
SPRINGFIELD, IL

62703-4259

wing
sent
recy.
tag-

I.D. Number
STATE USE ONLY
Date Received

Notification is required by Federal law for all underground tanks that have been d to store regulated substances since January 1, 1974, that are in the ground as of 1986, or that are brought into use after May 8, 1986. The information requested required by Section 9002 of the Resource Conservation and Recovery Act, (RCRA), amended.

The primary purpose of this notification program is to locate and evaluate underground tanks that store or have stored petroleum or hazardous substances. It is pected that the information you provide will be based on reasonably available rds, or, in the absence of such records, your knowledge, belief, or recollection.

Who Must Notify? Section 9002 of RCRA, as amended, requires that, unless emptied, owners of underground tanks that store regulated substances must notify signed State or local agencies of the existence of their tanks. Owner means— (a) in the case of an underground storage tank in use on November 8, 1984, or ough into use after that date, any person who owns an underground storage tank ed for the storage, use, or dispensing of regulated substances, and (b) in the case of any underground storage tank in use before November 8, 1984, at no longer in use on that date, any person who owned such tank immediately before e discontinuation of its use.

What Tanks Are Included? Underground storage tank is defined as any one or mbination of tanks that (1) is used to contain an accumulation of "regulated sub- nces," and (2) whose volume (including connected underground piping) is 10% or ore beneath the ground. Some examples are underground tanks storing: 1. gasoline, sed oil, or diesel fuel, and 2. industrial solvents, pesticides, herbicides or fumigants.

What Tanks Are Excluded? Tanks removed from the ground are not subject to otification. Other tanks excluded from notification are:

- farm or residential tanks of 1,100 gallons or less capacity used for storing motor fuel or noncommercial purposes;
- tanks used for storing heating oil for consumptive use on the premises where stored;
- septic tanks;

4. pipeline facilities (including gathering lines) regulated under the Natural Gas Pipeline Safety Act of 1968, or the Hazardous Liquid Pipeline Safety Act of 1979, or which is an intrastate pipeline facility regulated under State laws;
5. surface impoundments, pits, ponds, or lagoons;
6. storm water or waste water collection systems;
7. flow-through process tanks;
8. liquid traps or associated gathering lines directly related to oil or gas production and gathering operations;
9. storage tanks situated in an underground area (such as a basement, cellar, mineworking, drift, shaft, or tunnel) if the storage tank is situated upon or above the surface of the floor.

What Substances Are Covered? The notification requirements apply to under- ground storage tanks that contain regulated substances. This includes any substance defined as hazardous in section 101 (14) of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA), with the exception of those substances regulated as hazardous waste under Subtitle C of RCRA. It also includes petroleum, e.g., crude oil or any fraction thereof which is liquid at standard conditions of temperature and pressure (60 degrees Fahrenheit and 14.7 pounds per square inch absolute).

Where To Notify? Completed notification forms should be sent to the address given at the top of this page.

When To Notify? 1. Owners of underground storage tanks in use or that have been taken out of operation after January 1, 1974, but still in the ground, must notify by May 8, 1986. 2. Owners who bring underground storage tanks into use after May 8, 1986, must notify within 30 days of bringing the tanks into use.

Penalties: Any owner who knowingly fails to notify or submits false information shall be subject to a civil penalty not to exceed \$10,000 for each tank for which notification is not given or for which false information is submitted.

INSTRUCTIONS

Please type or print in ink all items except "signature" in Section V. This form must be completed for each location containing underground storage tanks. If more than 5 tanks are owned at this location, photocopy the reverse side, and staple continuation sheets to this form.

Indicate number of continuation sheets attached

I. OWNERSHIP OF TANK(S)

Owner Name (Corporation, Individual, Public Agency, or Other Entity)

Street Address

County

City State ZIP Code

Area Code Phone Number

Type of Owner (Mark all that apply ☒)

- ☐ Current ☐ State or Local Gov't ☐ Private or Corporate
- ☐ Former ☐ Federal Gov't (GSA facility I.D. no.) ☐ Ownership uncertain

II. LOCATION OF TANK(S)

(If same as Section I, mark box here ☐)

Facility Name or Company Site Identifier, as applicable

Street Address or State Road, as applicable

County

City (nearest) State ZIP Code

Indicate number of tanks at this location

Mark box here if tank(s) are located on land within an Indian reservation or on other Indian trust lands

III. CONTACT PERSON AT TANK LOCATION

Name (If same as Section I, mark box here ☐)

Job Title

Area Code

Phone Number

IV. TYPE OF NOTIFICATION

☐ Mark box here only if this is an amended or subsequent notification for this location.

V. CERTIFICATION (Read and sign after completing Section VI.)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Name and official title of owner or owner's authorized representative

Signature

Date Signed

CONTINUE ON REVERSE SIDE

VII. CERTIFICATION OF COMPLIANCE (COMPLETE FOR ALL NEW TANKS AT THIS LOCATION)

Installation (mark all that apply):

- ☐ The installer has been certified by the tank and piping manufacturers.
- ☐ The installer has been certified or licensed by the implementing agency.
- ☐ The installation has been inspected and certified by a registered professional engineer.
- ☐ The installation has been inspected and approved by the implementing agency.
- ☐ All work listed on the manufacturer's installation checklists has been completed.
- ☐ Another method was used as allowed by the implementing agency. Please specify:

11. Release Detection (mark all that apply):

- ☐ Manual tank gauging.
- ☐ Tank tightness testing with inventory controls.
- ☐ Automatic tank gauging.
- ☐ Vapor monitoring.
- ☐ Ground-water monitoring.
- ☐ Interstitial monitoring within a secondary barrier.
- ☐ Interstitial monitoring within secondary containment.
- ☐ Automatic line leak detectors.
- ☐ Line tightness testing.
- ☐ Another method allowed by the implementing agency. Please specify:

12. Corrosion Protection (if applicable)

- ☐ As specified for coated steel tanks with cathodic protection.
- ☐ As specified for coated steel piping with cathodic protection.
- ☐ Another method allowed by the implementing agency. Please specify:

13. I have financial responsibility in accordance with Subpart I. Please specify:

Method: _____
Insurer: _____
Policy Number: _____

14. OATH: I certify that the information concerning installation provided in Item 10 is true to the best of my belief and knowledge.

Installer: _____
Name _____ Date _____
Position _____
Company _____

Office of Illinois State Fire Marshal -
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703-4259

Facility #	2-001201
Permit #	8673 REL
Request Rec'd	12-14-90
Approval Date	01-17-91

PERMIT FOR INSTALLATION OF
UNDERGROUND STORAGE TANKS AND PIPING FOR PETROLEUM AND HAZARDOUS MATERIALS

Permission to install underground storage tank or tanks and piping is hereby granted. Such installation must be in accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A forty-eight (48) hour - 2 working day notice is required to confirm final date of the installation, for relining or upgrade for confirmation of our Inspector to be on site. You must contact the Division of Fire Prevention by phone; Chicago 312/814-2593, Marion 618/997-4371 ext.210, Springfield 217/785-4713.

Owner-Corporation, partnership or other business entity:

Arrow Gear Company

2301 Curtiss Street

Street Address
Downers Grove Il. 60515
State Zip
708/969-7640

Person, Firm or Company Performing Work:

New Process Tank Systems, Inc.

742 N. Yale

Street Address
Villa Park Il. 60181
State Zip
708/387-0026 363-65-3588
Registration No.

2) Name and location of facility where installation is to occur:

Same

Name
Street Address
City State Zip DuPage County
Contact Person Phone

THIS PERMIT IS VALID FOR SIX (6) MONTHS
FROM THE APPROVAL DATE.

PERMIT EXPIRES 07-17-91

Installation of tanks:

- a) Number and size of tanks being ~~replaced~~ relined: (1) 1,800 Gal. & (1) 1,000 Gal.
- b) Type of tanks: Existing steel
- c) Type of piping: N/A
- d) Type of leak detection being installed for each tank and piping: None
- e) Product to be stored for each tank Cooling oil and machine oil
- f) Corrosion protection being installed for each tank system (including piping):
Interior of tank will be lined with Armor Shield TL-300 coating
- f) Spill/Overfill prevention devices being installed for each tank: None

You must notify this office when completion of tank installation has taken place, on EPA Notification Form 7530. Please note a EPA Form 7530-1 has been forwarded to the name and address shown in Item 1.

A minimum distance of 200 feet from nearest neighbors potable water well or 75 feet from nearest potable water wells on owners property must be maintained for all tanks and piping being installed.

Sincerely,

W. Dale Tanke
W. Dale Tanke, Storage Tank Safety Engineer
(217) 785-5878

BA:jls

Fire Prevention Region Chicago
Fire Department
Division File
Dale Tanke